

Safety Instructions

Before operating this device, please consult the user manual for safety instructions. These guidelines will enable you to operate the product in a safe and correct manner in order to prevent harm to yourself and others.




Procedure for Changing Programs

< Fusion Program>



Tap the fusion program area on the touchscreen or press key and select Fusion Program.

< Heater Program>



Tap the heater program area on the touchscreen, or press key and select Heater Program



Select applicable fusion program.

Heater Program	All Programs	V	
001 S924F POWER 40MM	6	Ø	
002 S924F 40MM	6	Ø	
003 S924 POWER 40MM	6	Ø	
004 S924 40MM	6	Ø	•

Select applicable heater program.

Arc Check

An arc check is the function to adjust the arc power in order to ensure optimal splicing results. Electrode wear and environmental conditions such as temperature, humidity, and altitude, may affect the arc power.

Please perform the Arc Check at the beginning of your working day.



Open the windshield and set the fibers. Then enter "Arc Check".



Splicer automatically feeds the fibers and discharges an arc.




The result is indicated. If the result is negative, please perform the arc check again.

S124 Quick Reference Guide

To ensure optimal splicing results

< Cleaning V-groove>



Run fiber across V-groove to remove dust in V-groove.

< Cleaning Fiber Clamps>

Clean Fiber Clamps by using a cotton swab soaked with ethanol.



Cleaning brush




Fiber Clamp

Clean V-groove by using the cleaning brush provided or a cotton swab soaked with ethanol.

Maintenance


< Cleaning Electrodes>



Stick the tip of the electrode into the electrode sharpener and turn/twist the electrode 3-4 times.

< Cleaning Objective Lens >





< Replacement of Electrodes>





Remove the electrode form the electrode holder. Then replace with a new electrode. After replacement, press the key 10 times, after closing the windshield to remove any dust.

Attach the electrode holder in order from the front side to the back side.

Objective Lens

Remove both electrodes and V-groove. Then clean Objective Lens by using cotton swab soaked with ethanol.

S124 Quick Reference Guide

